

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರವರ ಕಛೇರಿ,
ನಂ.4 ಕಟ್ಟಡಗಳ ಉಪವಿಭಾಗ
ಲೋಕೋಪಯೋಗಿ ಇಲಾಖೆ, ಬೆಂಗಳೂರು-560 001.



ದೂರವಾಣಿ ಸಂಖ್ಯೆ: 080-22267585
ಇ-ಮೇಲ್: aeeno4bldg@gmail.com

ಲೋಕೋಪಯೋಗಿ ಇಲಾಖೆ

ಸಂ: ಸಕಾಅ/ಕಉವಿ-4/ಸ.ಇಂ/ಕ.ವೃಥೀಕರಣ ಪತ್ರ/2025-26/ 318

ದಿನಾಂಕ: 27/6/2025

Annexure D

BUILDING SAFETY CERTIFICATE


Certified that the existing building **Scholar Academy English School, No. 39, 39/1, Chikkabidarakallu, Behind Parle Factory, Tumkur Road, Bangalore – 560 073** is having block (s) Floor (s) as per details given below:

Detail of Block(s) in school	Block (1)	Block (2)	Block (3)	Block (4)	Block (5)	Block (6)
No. of Floor(s) in the Block	G+4	G+4	G+4	-	-	-

The building is owned/occupied by **Scholars Foundation** have complied with the Building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of **Karnataka Public Works Department** on 26.06.2025 in the presence of **Principal** and that the building/premises is fit for occupancy for running school with effect from date: 27.06.2025 for a period of **One year** in accordance with rule and subject to compliance of the specific conditions as appended.

1. Dampness was observed in washroom areas
2. Minor cracks were observed at some portions of the buildings
3. The Building is Safe for occupancy with the remedial measures to be taken for block 1, 2 & 3 immediately as per the expert report.

Issued on 27.06.2025 at Bangalore by


Assistant Executive Engineer,
No. 4 Building Sub-Division,
Bangalore.